

APPENDIX I-I

Correspondence

Robert P. Astorino
County Executive

Department of Environmental Facilities

Vincent Kopicki, P.E.
Acting Commissioner

June 29, 2021

Mr. Robert Peak
JMC
120 Bedford Road
Armonk, NY 10504

Re: Ossining Water Resource Recovery Facility
River Knoll Project
40 Croton Dam Road
Ossining (T)

Dear Mr. Peak:

Receipt of your June 28, 2021 request regarding the above referenced project is acknowledged. In accordance with your request, please be advised that Westchester County's Ossining Water Resource Recovery Facility has sufficient capacity to accommodate the proposed flow increase of 11,645 gallons per day to be generated by the above referenced project. The average daily flow for the facility in the 2020 calendar year was 4.0 million gallons per day (MGD), and the SPDES permitted flow for the plant is 7.0 MGD monthly average.

However, as we have done in other County sewer districts, we request that the additional flow to the system be offset by reductions in inflow/infiltration (I&I). The removal for this project should be on a three for one ratio similar to the previous requirements by NYSDEC for sewer extension approvals in the New Rochelle sewer district. We feel this project warrants the same consideration. For units that are considered fair and affordable housing units, the removal ratio for those units can be reduced to a one to one ratio.

Please contact the undersigned at (914) 813-5419 if you need further information.

Very truly yours,



Marian Pompa, Jr., P.E.
Associate Engineer

cc: Dave Kvinge, WC Dept. of Planning
file

Division of Solid Waste
Wastewater Treatment
Water Agency

270 North Avenue
New Rochelle, New York 10801

Telephone: (914) 813-5400

Fax: (914) 813-5460

Website: westchestergov.com

